



## Legislation Text

---

**File #:** Res. 2018-19R, **Version:** 1

---

### **AGENDA CAPTION:**

Consider approval of Resolution 2018-19R, approving Change Order No. 2 to the River Ridge to Loop 82 Utility Relocation Project in order to facilitate the necessary environmental services required because of the presence of LPSTs (leaking petroleum storage tanks) in the vicinity of the project and increasing the total amount of the project to \$70,671.12; ratifying the City's execution of the change order and increase in dollar amount; and declaring an effective date.

**Meeting date:** 2/6/2018

**Department:** Engineering & CIP

### **Amount & Source of Funding**

**Funds Required:** \$20,547.20

**Account Number:** C248

**Funds Available:** 162,500

**Account Name:** Water Improvements

### **Fiscal Note:**

**Prior Council Action:** NA

**City Council Goal:** [Please select goal from dropdown menu below]

Goal #5 Maintain & Improve City's Infrastructure

Choose an item.

Choose an item.

**Comprehensive Plan Element (s):** [Please select the Plan element(s) and Goal # from dropdown menu below]

- ☐ Economic Development - Choose an item.
- ☐ Environment & Resource Protection - Choose an item.
- ☐ Land Use - Choose an item.
- ☐ Neighborhoods & Housing - Choose an item.
- ☐ Parks, Public Spaces & Facilities - Choose an item.
- ☐ Transportation - Choose an item.
- ☒ Not Applicable

**Master Plan:** *[Please select the corresponding Master Plan from the dropdown menu below (if applicable)]*

Water Master Plan

**Background Information:**

CP&Y Inc., was hired to provide the necessary engineering and technical services for design, bidding and construction phase services for the relocation and upsizing of approximately 350 linear feet of existing 8" waterline with proposed 16" waterline crossing underneath IH35 at Uhland Road, and approximately 250 linear feet of 8" and 12" waterline relocation along IH35 northbound frontage road at Uhland Road.

A change in service is requested to include the necessary environmental services required to install groundwater monitoring wells on both sides of IH-35 near Crepe Myrtle as required by TxDOT due to the presence of documented LPSTs (Leaking Petroleum Storage Tanks) in the vicinity of the project.

The monitoring wells will test for various contaminants, and the results will be included in an updated environmental re-evaluation of an already approved Categorical Exclusion (CE) for a northbound ramp reversal project along IH35 from Loop 82 to River Ridge. The monitoring wells are a requirement of TxDOT based on the initial CE re-evaluation performed under CIS Authorization No. 1. The CE is required to construct the proposed 16" waterline crossing underneath IH35. The field work and CE re-evaluation will be completed in accordance with TxDOT's requirements.

Previous change in service includes re-evaluation of an approved CE to include a proposed 16" waterline crossing as a joint bid with the TxDOT IH35 from Loop 82 to River Ridge Ramp Reversal project; in the amount of \$10,391.46

**Council Committee, Board/Commission Action:**

NA

**Alternatives:**

NA

**Recommendation:**

Staff recommends approval of change in service # 2